

This Addendum contains changes to the requirements of the Bidding Documents that have been issued to date. Such changes are to be incorporated into the Bid/Construction project and shall apply to the Work with the same meaning and force as if they had been included in the original documents. Wherever this Addendum modifies a portion of a paragraph of the Project Manual or a portion of any Drawing, the remainder of the paragraph or Drawing shall remain in force. This Addendum is hereby included in and made a part of the Bidding Documents whether or not attached hereto.

Addendum No. 2

APRIL 05, 2024

Part 1 - Non Contract Documents / Bidding / Proposal

- a. Refer to the attached - Pre-Bid conference attendance sheet.

Part 2 –Specifications

- a. NONE

Part 3 - Drawings:

1. Drawing SK-S-1.0,
 - a. **ADD** the drawing “SK-S-1.0 LOOSE LINTEL SCHEDULE” as part of the bid drawing set.
2. Drawing A801 – FINISH SCHEDULE
 - a. **ADD** – TERRAZO TILE – TT1 – WAUSAU TILE - MICRO SERIES TERRAZZO TILE – to finish schedule. Size to match existing – Color to be determined by Architect from manufacturer's standard colors – to be used for VESTIBLE (B101) floor finish after executing plumbing scope.

Part 4 – Clarifications:

1. **Question** – Typically, the GC is responsible for Saw-cutting and slab removal, Plumbing contractor to excavate and backfill then GC to pour concrete and match the existing floor finish. Could you clarify the scope and provide information regarding the existing floor finish outside of County Elections?

Response A– Typically, the GC is responsible for Saw-cutting and slab removal, concrete pours and match the existing floor finish.

Response B– At the scope area in Basement level, Plumbing contractor shall be responsible for trenching, executing and backfilling. GC shall be responsible for cutting, slab removals and slab reconstruction and floor finish. Refer to Part 3 – Drawings – 2.a of Addendum# 2.

2. **Question** – A Substitution Request for metal lockers products on the project.

Response – Refer to Section 002000 INSTRUCTIONS TO BIDDERS FOR CONSTRUCTION CONTRACT – Article 9 - The Contract for the Work, as awarded, will be on the basis of materials and equipment specified or described in the Bidding Documents without consideration during the bidding and Contract award process of possible substitute or “or-equal” items. Substitution requests are considered from bid awarded contractors only.

3. **Question** – A Substitution Request for acoustic products on the project.

Response – Refer to Part 4 – Clarifications – Question (2) of Addendum# 2 above.

ATTACHMENTS

- Pre-Bid conference attendance sheet
- SK-S-1.0 LOOSE LINTEL SCHEDULE

END OF ADDENDUM No. 2

Andrew Petruzzelli, AIA
Project Architect

PROJECT NO. 23-015
 PROJECT NAME Auburn City Court Expansion
 MEETING Pre-Bid Conference
 DATE March 28th, 2024
 TIME 1 pm

Sign In Sheet

Thaler Reilly Wilson
 Architecture Preservation, LLP
 25 Monroe Street, Suite 202
 Albany, NY 12210

Name	Company	Phone	Email
Joe Timinar	Two Brothers	315 736-5288	Joe@TBCPerma.com
Jim Melfi	PASC	315 664-4043	jmelfi@pasobus.com
Gary Dickett	Cayuga County	315 730-3282	gdickett@cayugacountyny.us
KENNETH JANNER	COA		
STEPHEN BRISTOL	AVENTUS NY	315-335-8873	STEPHEN.BRISTOL@AVENTUSNY.COM
Aristina Luck	City of Auburn	315-253-5317	cs.luck@auburnny.gov
Maggie Smith	CITY OF Auburn COAPS	315-255-4110	msmith@auburnny.gov
Brian Hicks	CITY OF Auburn COAPS	"	bhicks@auburnny.gov
Mark Perry	CITY OF Auburn COAPS	"	mperry@auburnny.gov
GENO FRANCELLE	COFA	315-255-4135	gfrancelle@auburnny.gov
Greg Gallinger	Gallinger - Lilly Plbs + Hqs.	315-277-0124	ggallinger10@gmail.com
Levi Fahmer	AAC	585-354-7560	Levi.Fahmer@AAC-Contracting.com
Tim Siracusa	SMI	315-252-5046	tim.siracusa@gmail.com

MASONRY OPENING STEEL ANGLE LINTEL SCHEDULE

CLEAR MASONRY OPENING WIDTH	LINTEL FOR 4" MASONRY WALLS	LINTEL FOR 6" MASONRY WALLS	LINTEL FOR 8" MASONRY WALLS	LINTEL FOR 10" MASONRY WALLS	LINTEL FOR 12" MASONRY WALLS
8" TO 1'-5"	FLAT $\frac{5}{16}$ " PLATE	FLAT $\frac{5}{16}$ " PLATE	FLAT $\frac{5}{16}$ " PLATE	FLAT $\frac{5}{16}$ " PLATE	FLAT $\frac{5}{16}$ " PLATE
1'-6" TO 2'-11"	L3 $\frac{1}{2}$ x3 $\frac{1}{2}$ x $\frac{1}{4}$ "	WT4x9	(2) L3 $\frac{1}{2}$ x3 $\frac{1}{2}$ x $\frac{1}{4}$ "	L5x3 $\frac{1}{4}$ " and L4x3x $\frac{1}{4}$ " (LLH)	L6x3 $\frac{1}{2}$ x $\frac{5}{16}$ " and L5x3 $\frac{1}{2}$ x $\frac{5}{16}$ " (LLH)
3'-0" TO 3'-11"	L3 $\frac{1}{2}$ x3 $\frac{1}{2}$ x $\frac{5}{16}$ "	WT4x9	(2) L3 $\frac{1}{2}$ x3 $\frac{1}{2}$ x $\frac{5}{16}$ "	L5x3 $\frac{1}{4}$ " and L4x3x $\frac{1}{4}$ " (LLH)	L6x3 $\frac{1}{2}$ x $\frac{5}{16}$ " and L5x3 $\frac{1}{2}$ x $\frac{5}{16}$ " (LLH)
4'-0" TO 4'-11"	L3 $\frac{1}{2}$ x3 $\frac{1}{2}$ x $\frac{3}{8}$ "	WT4x10.5	(2) L3 $\frac{1}{2}$ x3 $\frac{1}{2}$ x $\frac{3}{8}$ "	L5x3 $\frac{1}{4}$ " and L4x3x $\frac{1}{4}$ " (LLH)	L6x3 $\frac{1}{2}$ x $\frac{5}{16}$ " and L5x3 $\frac{1}{2}$ x $\frac{5}{16}$ " (LLH)
5'-0" TO 5'-11"	L4x3 $\frac{1}{2}$ x $\frac{5}{16}$ " (LLV)	WT5x11	(2) L4x3 $\frac{1}{2}$ x $\frac{5}{16}$ " (LLV)	L5x3 $\frac{1}{2}$ x $\frac{1}{4}$ " and L4x3 $\frac{1}{2}$ x $\frac{1}{4}$ " (LLH)	L6x3 $\frac{1}{2}$ x $\frac{3}{8}$ " and L5x3 $\frac{1}{2}$ x $\frac{3}{8}$ " (LLH)
6'-0" TO 6'-11"	L4x3 $\frac{1}{2}$ x $\frac{3}{8}$ " (LLV)	WT5x11	(2) L4x3 $\frac{1}{2}$ x $\frac{3}{8}$ " (LLV)	L5x3 $\frac{1}{2}$ x $\frac{3}{8}$ " and L4x3 $\frac{1}{2}$ x $\frac{3}{8}$ " (LLH)	L6x3 $\frac{1}{2}$ x $\frac{3}{8}$ " and L5x3 $\frac{1}{2}$ x $\frac{3}{8}$ " (LLH)
7'-0" TO 7'-11"	L5x3 $\frac{1}{2}$ x $\frac{5}{16}$ " (LLV)	WT8x13	(2) L5x3 $\frac{1}{2}$ x $\frac{5}{16}$ " (LLV)	L6x6x $\frac{5}{16}$ " and L6x3 $\frac{1}{2}$ x $\frac{5}{16}$ " (LLV)	L6x6x $\frac{3}{8}$ " and L5x5x $\frac{3}{8}$ "
8'-0" TO 8'-11"	L5x3 $\frac{1}{2}$ x $\frac{3}{8}$ " (LLV)	WT8x13	(2) L5x3 $\frac{1}{2}$ x $\frac{3}{8}$ " (LLV)	L6x6x $\frac{3}{16}$ " and L6x3 $\frac{1}{2}$ x $\frac{3}{16}$ " (LLV)	L6x6x $\frac{3}{8}$ " and L5x5x $\frac{3}{8}$ "
9'-0" TO 9'-11"	L6x3 $\frac{1}{2}$ x $\frac{3}{8}$ " (LLV)	WT8x13	(2) L6x3 $\frac{1}{2}$ x $\frac{3}{8}$ " (LLV)	L6x6x $\frac{3}{8}$ " and L6x3 $\frac{1}{2}$ x $\frac{3}{8}$ " (LLV)	L6x6x $\frac{3}{8}$ " and L5x5x $\frac{3}{8}$ "

LOOSE LINTEL NOTES:

- OPENINGS FOR PASSAGE OF DUCTS AND OTHER UTILITIES THAT REQUIRE LINTELS IN THIS TABLE ARE NOT NOTED ON THE PLANS. PROVIDE LINTELS FOR ALL OPENINGS THROUGH EXISTING MASONRY WALLS FOR THE PASSAGE OF DUCTS AND OTHER UTILITIES. ASSUME 50 MASONRY WALL OPENINGS ARE REQUIRED.
- NOTE THAT EXISTING MASONRY WALLS MAY BE COMPRISED OF CLAY BRICK, CLAY TILE OR TERRACOTTA, CMU, CONCRETE, OR OTHER MASONRY MATERIALS.
- MEMBER SIZES GIVEN ARE ONLY FOR SUPPORT OF MASONRY OPENING WITH NO ADDITIONAL SUPERIMPOSED LOADS ABOVE.
- SEE PLANS FOR SPECIAL LINTELS SUPPORTING ADDITIONAL POINT OR UNIFORM LOADS.
- PROVIDE 8" MIN BEARING OF LINTELS AT EACH END U.N.O.
- HOT-DIP GALVANIZE LINTELS IN EXTERIOR WALLS U.N.O.
- PROVIDE CUTTING AND PATCHING OF ALL SURROUNDING MATERIALS AND FINISHES REQUIRED TO INSTALL LINTELS.
- PROVIDE TEMPORARY SHORING OF MASONRY CONSTRUCTION ABOVE TO ACCOMMODATE SAFE INSTALLATION WHILE PREVENTING SETTLEMENT, MOVEMENT, CRACKING, OR DISTORTION OF MATERIALS.
- UNLESS NOTED OTHERWISE, TOOTH NEW INFILL MASONRY INTO EXISTING MATERIAL AND MATCH THE EXISTING BOND PATTERN.
- CUT ALL NEW MASONRY TO FIT WITHIN AND MATCH EXISTING MASONRY BOND PATTERN.
- CUT ALL NEW MASONRY AS REQUIRED TO FILL SOLID AROUND INDIVIDUAL LINTEL MEMBERS. SUPPLEMENT WITH MORTAR AND/OR SOLID GROUT TO COMPLETELY FILL ALL VOIDS, TYP.



PROJECT NAME:
EXPANSION OF CITY COURT
AUBURN, NEW YORK
157 GENESEE ST#2, AUBURN, NY 13021


DRAWING TITLE:
LOOSE LINTEL SCHEDULE
(PART OF ADDENDUM 2)

DATE:
2024-04-01
SLD PROJECT No.
08024033

SCALE:
NO SCALE
DRAWN BY:
JAB

DRAWING NUMBER
SK-S-1.0

© COPYRIGHT 2024
SPRING LINE DESIGN
"ALL RIGHTS RESERVED"
AND "UNAUTHORIZED
DUPLICATION IS A VIOLATION
OF APPLICABLE LAWS"



73 troy road, suite 2h
east greenbush, ny 12061
518.487.4755 telephone
518.670.0122 facsimile
springlinedesign.com